



Burlington, WA	Corporate Laboratory (a)	1620 S Walnut St	Burlington, WA 98233	800.755.9295 • 360.757.1400
Bellingham, WA	Microbiology (b)	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (d)	540 SW Third Street	Corvallis, OR 97333	541.753.4946



Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: Rolling Hills Glencairn C/O EWS
1126 N Sidney
Oak Harbor, WA 98277

Reference Number: 19-18517

Project: Rolling Hills Glencairn Bacteria

System Name: ROLLING HILLS-GLENCAIRN
System ID Number: 74000F
DOH Source Number: 00 - Distribution Sample (Bacteria)
Sample Type: D - Drinking Water
Sample Purpose: C - Compliance
Sample Location: 1065 Sidney
County: Island
Sampled By: EWS
Sampler Phone:

Repeat Sample Number:
Lab Number: 164-36642
Field ID: Rolling Hills Glencairn B
Date Collected: 5/21/19 10:50
Date Received: 5/21/19
Date Set: 5/21/19 17:33
Date Analyzed: 5/22/19 12:28
Report Date: 5/23/19
Comment: Cl2: 0.04
Approved By: clh,rml

Authorized by:

Jessica L. Nunamaker
Microbiologist/QA Officer

DOH#	PARAMETER	RESULT	Qualifier	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	Satisfactory, Coliforms Absent		per 100mL	jfh	SM9223 B	m_190521b	
3	E. COLI	Absent		per 100mL		SM9223 B	m_190521b	

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>

San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>

Skagit Co: <http://www.skagitcounty.net/drinkingwater> or 360-336-9380

Snohomish Co: 425-339-5250

Whatcom Co: http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp

WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

NOTES:

If the result is Unsatisfactory a repeat sample is required for Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.

If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.

*If data qualifiers are present, see accompanying Qualifier Definition report.