



Burlington, WA	Corporate Laboratory (a)	1620 S Walnut St	Burlington, WA 98233	800.755.9295 • 360.757.1400
Bellingham, WA	Microbiology (b)	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (d)	540 SW Third Street	Corvallis, OR 97333	541.753.4946



## Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: Rolling Hills Glencairn C/O EWS  
1126 N Sidney  
Oak Harbor, WA 98277

Reference Number: 19-26490

Project: Rolling Hills Glencairn Bacteria

System Name: ROLLING HILLS-GLENCAIRN  
System ID Number: 74000F  
DOH Source Number: 00 - Distribution Sample (Bacteria)  
Sample Type: D - Drinking Water  
Sample Purpose: C - Compliance  
Sample Location: 953 Riepma  
County: Island  
Sampled By: EWS  
Sampler Phone:

Repeat Sample Number:

Lab Number: 164-51619

Field ID: Rolling Hills Glencairn B

Date Collected: 7/16/19 11:35

Date Received: 7/16/19

Date Set: 7/16/19 17:28

Date Analyzed: 7/17/19 11:59

Report Date: 7/18/19

Comment: Cl2: 0.12

Approved By: clh,jln

Authorized by:

Cynthia L Hansen  
Microbiologist/Office Manager

DOH#	PARAMETER	RESULT	Qualifier	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	<b>Satisfactory, Coliforms Absent</b>		per 100mL	jfh	SM9223 B	m_190716b	
3	E. COLI	<b>Absent</b>		per 100mL		SM9223 B	m_190716b	

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>

San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>

Skagit Co: <http://www.skagitcounty.net/drinkingwater> or 360-336-9380

Snohomish Co: 425-339-5250

Whatcom Co: [http://www.co.whatcom.wa.us/health/environmental/drinking\\_water/index.jsp](http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp)

WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

### NOTES:

If the result is Unsatisfactory, three (3) repeat samples and groundwater source samples are required for Group A Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.

If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.

\*If data qualifiers are present, see accompanying Qualifier Definition report.