



Burlington, WA Corporate Laboratory (a)  
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)  
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)  
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)  
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR Microbiology (e)  
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



FL NELAP E871040

Page 1 of 1

## DISINFECTION BY-PRODUCT COMPOUNDS REPORT

Client Name: Rolling Hills Glencairn C/O EWS  
1126 N Sidney  
Oak Harbor, WA 98277

Reference Number: 20-09579

Project: Rolling Hills Glencairn HAA/THM

Date Collected: 3/17/20 10:25  
System ID Number: 74000F  
Lab Number: 046-18699  
Sample Location: 807 Riepma End of Dist System Glen Cairn  
Sample Purpose: C - Compliance  
Sample Composition: Distribution Sample  
Approved By: pdm  
Authorized By:

Lawrence J Henderson, PhD  
Director of Laboratories, Vice President

Field ID:  
System Group Type: A  
System Name: ROLLING HILLS-GLENCAIRN  
County: ISLAND  
Source Number: 92 - Distribution Sample  
Multiple Sources:  
Date Received: 3/17/2020 3:23:00P  
Date Analyzed: 04/02/20  
Date: Reported: 4/8/20  
Sample Type: A - After treatment  
Sample Collected By: EWS  
Sampler Phone:

DOH#	COMPOUNDS	RESULTS	UNITS	SRL	Trigger	MCL	Method	Analyst	Lab	Batch	Comment
	<b>Halo-Acetic Acids</b>										
411	MONOCHLOROACETIC ACID	ND	ug/L	2			552.3	KRM	A	552_200325	
412	DICHLOROACETIC ACID	ND	ug/L	1			552.3	KRM	A	552_200325	
413	TRICHLOROACETIC ACID	ND	ug/L	1			552.3	KRM	A	552_200325	
414	MONOBROMOACETIC ACID	ND	ug/L	1			552.3	KRM	A	552_200325	
415	DIBROMOACETIC ACID	1.1	ug/L	1			552.3	KRM	A	552_200325	
416	HAA(5)	1.1	ug/L	1	45	60	552.3	KRM	A	552_200325	
	<b>Other</b>										
417	BROMOCHLOROACETIC ACID	ND	ug/L	1			552.3	KRM	A	552_200325	
	<b>EPA Regulated - Under Trihalomethanes Program</b>										
27	CHLOROFORM	ND	ug/L	0.5			524.2	HY	A	THM_200320	
28	BROMODICHLOROMETHANE	ND	ug/L	0.5			524.2	HY	A	THM_200320	
29	CHLORODIBROMOMETHANE	1.1	ug/L	0.5			524.2	HY	A	THM_200320	
30	BROMOFORM	3.6	ug/L	0.5			524.2	HY	A	THM_200320	
31	TOTAL TRIHALOMETHANE	4.7	ug/L		60	80	524.2	HY	A	THM_200320	

### NOTES:

If a compound is detected > or = to the State Reporting Level, SRL, specified increased monitoring frequencies may occur per DOH.

MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.

Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.

ND (Not Detected): indicates that the parameter was not detected above the State Reporting Limit (SRL).

An \* in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

Lab - Indicates where parameter was analyzed. See header address for lab code.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

If you have any questions concerning this report contact Lawrence J Henderson, PhD, Director of Laboratories, Vice President, at the toll-free phone number above.

FORM: cODBP.rpt