



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802
Corvallis, OR Microbiology/Chemistry (d)
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946
Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



OR NELAP 4072

Page 1 of 2

LEAD & COPPER RULE REPORT

Client Name: Rolling Hills Glencairn C/O EWS
1126 N Sidney
Oak Harbor, WA 98277

Reference Number: 20-24676

Project: Rolling Hills Glencairn
PbCu Rule

System ID Number: **74000F**
Lab Number: 046-46888
Sample Purpose: C - Compliance
Sample Composition: Single Source

Approved By: ljh

Authorized By:

Lawrence J Henderson, PhD
Director of Laboratories, Vice President

Field ID:
System Group Type: A
System Name: ROLLING HILLS-GLENCAIRN
County: ISLAND
Source Number: 93 - Standing Water (Pb&Cu)
Multiple Sources:
Date Received: 7/21/2020
Date Reported: 7/31/20
Sample Type: A - After treatment
Sample Collected By: Christine Cooper
Sampler Phone:

Lab Number	Date Collected	Site / Location	PRM #	Analyte Name	Result	Units	AL	SRL	METHOD	Lab	Analyzed	Comments
046-46888	7/14/2020	- 1664 Allyson St	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	7/29/20	
			23	COPPER	0.0818	mg/L	1.3	0.005	200.8	a	7/29/20	
046-46889	7/15/2020	- 969 Riepma Ave	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	7/29/20	
			23	COPPER	0.272	mg/L	1.3	0.005	200.8	a	7/29/20	
046-46890	7/14/2020	- 1158 Paul Avenue	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	7/29/20	
			23	COPPER	0.0242	mg/L	1.3	0.005	200.8	a	7/29/20	
046-46891	7/15/2020	- 930 Diane Ave	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	7/29/20	
			23	COPPER	0.0179	mg/L	1.3	0.005	200.8	a	7/29/20	
046-46892	7/15/2020	- 926 Diane Ave	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	7/29/20	
			23	COPPER	0.005	mg/L	1.3	0.005	200.8	a	7/29/20	
046-46893	7/14/2020	- 1630 Douglas St	9	LEAD	0.0024	mg/L	0.015	0.001	200.8	a	7/29/20	
			23	COPPER	0.0287	mg/L	1.3	0.005	200.8	a	7/29/20	
046-46894	7/14/2020	- 969 Donald Ave	9	LEAD	0.0013	mg/L	0.015	0.001	200.8	a	7/29/20	
			23	COPPER	0.0704	mg/L	1.3	0.005	200.8	a	7/29/20	
046-46895	7/18/2020	- 1021 Shawn	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	7/29/20	
			23	COPPER	0.0195	mg/L	1.3	0.005	200.8	a	7/29/20	
046-46896	7/14/2020	- 940 Diane Ave	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	7/29/20	
			23	COPPER	0.0281	mg/L	1.3	0.005	200.8	a	7/29/20	

NOTES:

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Specified Reporting Limit (SRL).

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

If you have any questions concerning this report contact Lawrence J Henderson, PhD, Director of Laboratories, Vice President, at the toll-free phone number above.

FORM: cIQC_PBCU.rpt

