



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946


Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



INORGANIC COMPOUNDS (IOC) REPORT

Client Name: Rolling Hills Glencairn C/O EWS
1126 N Sidney
Oak Harbor, WA 98277

Reference Number: 20-15948
Project: Rolling Hills Glencairn

Date Collected: 5/19/20 10:30
System ID Number: **74000F**
Lab Number: **156-30575**
Sample Location: S04
Sample Purpose: C - Compliance
Sample Composition: Single Source
Approved by: hjb
Authorized by: 
Lawrence J Henderson, PhD
Director of Laboratories, Vice President

Field ID:
System Group Type: A
System Name: ROLLING HILLS-GLENCAIRN
County: ISLAND
Source Number: **04**
Multiple Sources:
Date Received: 5/19/20
Report Date: 6/17/20
Sample Type: A - After treatment
Sampled By: EWS
Sampler Phone: 360-929-1116

DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Lab	Analyzed	COMMENT
	Radiological RADIUM 228 GROSS ALPHA GROSS BETA	ND ND ND	pCi/L pCi/L pCi/L	1 3 4		15 50	val cla cla	904.0 900.0 900.0		06/16/20 06/08/20 06/08/20	Analyzed by Pace Analyzed by Pace Analyzed by Pace

NOTES:

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).
MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.
Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.
ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).
An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.
If you have any questions concerning this report contact Lawrence J Henderson, PhD, Director of Laboratories, Vice President, at the toll-free phone number above.



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



INORGANIC COMPOUNDS (IOC) REPORT

Client Name: Rolling Hills Glencairn C/O EWS
1126 N Sidney
Oak Harbor, WA 98277

Reference Number: 20-15948
Project: Rolling Hills Glencairn

Date Collected: 5/19/20 10:35
System ID Number: **74000F**
Lab Number: **156-30576**
Sample Location: S05
Sample Purpose: C - Compliance
Sample Composition: Single Source

Approved by: hjb

Authorized by:

Lawrence J Henderson, PhD
Director of Laboratories, Vice President

Field ID:
System Group Type: A
System Name: ROLLING HILLS-GLENCAIRN
County: ISLAND
Source Number: **05**
Multiple Sources:
Date Received: 5/19/20
Report Date: 6/17/20
Sample Type: A - After treatment
Sampled By: EWS
Sampler Phone: 360-929-1116

DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Lab	Analyzed	COMMENT
	Radiological RADIUM 228 GROSS ALPHA GROSS BETA	ND ND 6.13	pCi/L pCi/L pCi/L	1 3 4		15 50	val cla cla	904.0 900.0 900.0		06/16/20 06/08/20 06/08/20	Analyzed by Pace Analyzed by Pace Analyzed by Pace

NOTES:

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).

MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.

Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.

ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

If you have any questions concerning this report contact Lawrence J Henderson, PhD, Director of Laboratories, Vice President, at the toll-free phone number above.