



Exact Scientific Services, Inc.

1355 Pacific Place
Suite 101
Ferndale, WA 98248

Phone: (360) 733-1205

Fax: (888) 818-2978

Email: lab@exactscientific.com

Water Chemical Analysis

174 84801

Client: King Water Company
PO Box 2243
Oak Harbor, WA 98277

Invoice Number: 21-21109
PO Number:
Project Name: HAA/TTHM

Approved By:

PWS Information

Date Collected: 12/15/2021
System Number: 74000
Lab Sample Number: 174 84801
Sample Location: Sample: 1630 Douglas
Sample Purpose: Routine Compliance
Sample Composition: Samples from a single source

Sample Collected by:

System Group Type:

System Name: ROLLING HILLS-GLENCAIRN

County: ISLAND
Source Number: 92
Date Received: 12/16/2021
Date Analyzed: 12/17/2021
Date Reported: 1/3/2022
Sample Type: Post Treatment/Finished Water Sample

DOH #	Analyte	Results	Units	SRL	Trigger	MCL	Method	Analyst
<u>Total Trihalo Methane (TTHM's)</u>								
27	CHLOROFORM	1.5	ug/L	0.5	0.5		EPA_524.2_TTHM	GL
28	BROMODICHLOROMETHANE	2.2	ug/L	0.5	0.5		EPA_524.2_TTHM	GL
29	DIBROMOCHLOROMETHANE	2.3	ug/L	0.5	0.5		EPA_524.2_TTHM	GL
30	BROMOFORM	1.0	ug/L	0.5	0.5		EPA_524.2_TTHM	GL
31	TOTAL TRIHALOMETHANE	7.0	ug/L	0.5	0.5	80	EPA_524.2_TTHM	GL
<u>HaloAcetic Acids (HAA's)</u>								
411	MONOCHLOROACETIC ACID	ND	ug/L	2			EPA_552.3_DBP	GL
412	DICHLOROACETIC ACID	ND	ug/L	1			EPA_552.3_DBP	GL
413	TRICHLOROACETIC ACID	2.7	ug/L	1			EPA_552.3_DBP	GL
414	MONOBROMOACETIC ACID	ND	ug/L	1			EPA_552.3_DBP	GL
415	DIBROMOACETIC ACID	ND	ug/L	1			EPA_552.3_DBP	GL
416	HAA(5)	2.7	ug/L	1	15	60	EPA_552.3_DBP	GL
417	BROMOCHLOROACETIC ACID	ND	ug/L	1			EPA_552.3_DBP	GL

MCL = (Maximum Contaminant Level) allowed by the State of Washington.

ND = (Not Detected) Compound was analyzed and not detected at a level greater than or equal to the SRL.

SRL = (State Reporting Level) The minimum reporting level required by Washington State Department of Health (DOH).

Trigger Level = DOH drinking water response level. System with compounds detected at concentrations in excess of this level are required to take additional samples.

< = (less than) Indicates the analyte was below the detection limit.

OT = Out of Hold Time

174 84801



Exact Scientific Services, Inc.

1355 Pacific Place
Suite 101
Ferndale, WA 98248

Phone: (360) 733-1205

Fax: (888) 818-2978

Email: lab@exactscientific.com

Water Chemical Analysis

174 84801

Client: King Water Company
PO Box 2243
Oak Harbor, WA 98277

Invoice Number: 21-21109
PO Number:
Project Name: HAA/TTHM

Approved By:

PWS Information

Date Collected: 12/15/2021
System Number: 74000
Lab Sample Number: 174 84801
Sample Location: Sample: 1630 Douglas
Sample Purpose: Routine Compliance
Sample Composition: Samples from a single source

Sample Collected by:

System Group Type:

System Name: ROLLING HILLS-GLENCAIRN

County: ISLAND
Source Number: 92
Date Received: 12/16/2021
Date Analyzed: 12/17/2021
Date Reported: 1/3/2022
Sample Type: Post Treatment/Finished Water Sample

DOH #	Analyte	Results	Units	SRL	Trigger	MCL	Method	Analyst
<u>Total Trihalo Methane (TTHM's)</u>								
27	CHLOROFORM	1.5	ug/L	0.5	0.5		EPA_524.2_TTHM	GL
28	BROMODICHLOROMETHANE	2.2	ug/L	0.5	0.5		EPA_524.2_TTHM	GL
29	DIBROMOCHLOROMETHANE	2.3	ug/L	0.5	0.5		EPA_524.2_TTHM	GL
30	BROMOFORM	1.0	ug/L	0.5	0.5		EPA_524.2_TTHM	GL
31	TOTAL TRIHALOMETHANE	7.0	ug/L	0.5	0.5	80	EPA_524.2_TTHM	GL
<u>HaloAcetic Acids (HAA's)</u>								
411	MONOCHLOROACETIC ACID	ND	ug/L	2			EPA_552.3_DBP	GL
412	DICHLOROACETIC ACID	ND	ug/L	1			EPA_552.3_DBP	GL
413	TRICHLOROACETIC ACID	2.7	ug/L	1			EPA_552.3_DBP	GL
414	MONOBROMOACETIC ACID	ND	ug/L	1			EPA_552.3_DBP	GL
415	DIBROMOACETIC ACID	ND	ug/L	1			EPA_552.3_DBP	GL
416	HAA(5)	2.7	ug/L	1	15	60	EPA_552.3_DBP	GL
417	BROMOCHLOROACETIC ACID	ND	ug/L	1			EPA_552.3_DBP	GL

MCL = (Maximum Contaminant Level) allowed by the State of Washington.

ND = (Not Detected) Compound was analyzed and not detected at a level greater than or equal to the SRL.

SRL = (State Reporting Level) The minimum reporting level required by Washington State Department of Health (DOH).

Trigger Level = DOH drinking water response level. System with compounds detected at concentrations in excess of this level are required to take additional samples.

< = (less than) Indicates the analyte was below the detection limit.

OT = Out of Hold Time

174 84801