

1355 Pacific Place Suite 101 Ferndale, WA 98248

Phone: (360) 733-1205 Fax: (888) 818-2978

Email: lab@exactscientific.com

## Water Bacteriological Analysis

Client:

King Water Company

PO Box 2243

Oak Harbor, WA 98277

**Invoice Number:** 

22-14757

PO Number:

Project Name:

DW

Report Date:

8/31/2022

Approved By:

the Carlo

Dags 1 af 1

**Sample Information** 

Date Collected:

8/29/2022

Sample Purpose:

Routine Compliance

Sample Type:

Post Treatment/Finished Water Sample

Sample Composition:

Coliform Samples

Sample Collected by:

JEREMY

Source Number:

00

NP - Not detected above the listed detection limit

Date Received:

8/30/2022

Suitability:

Yes

Chlorine Res:

0.06

Repeat:

Repeat Lab #:

Repeat Date:

System Number: 74000

System Name: ROLLING HILLS-GLENCAIRN

l <sup>4</sup> : 58175		Sample: 1585 STEPHEN AVE.				
Analyte	Results	Units	<b>Detection Limit</b>	Method	Analyst	Date Analyzed
TOTAL COLIFORM	Satisfactory	/100ml	1	SM_9223B	MW	8/31/2022
E. COLI	Absent	/100ml	1	SM_9223B	MW	8/31/2022