



Water Chemical Analysis

174 79874

Client: King Water Company
PO Box 2243
Oak Harbor, WA 98277

Phone: (360) 914-1395

Email: jeremy@kingwater.com

Invoice Number: 22-20248
PO Number:
Project Name: TTHM/HAAApproved By: 

PWS Information

Date Collected: 11/28/2022
System Number: 74000
Lab Sample Number: 174 79874
Sample Location: Sample: Rolling Hills 803 Riepma
Sample Purpose: Routine Compliance
Sample Composition: Flowing Distribution Sample

Sample Collected by:

System Group Type:

System Name: ROLLING HILLS-GLENCAIRN

County: ISLAND
Source Number: 92
Date Received: 11/29/2022
Date Analyzed: 12/1/2022
Date Reported: 12/20/2022
Sample Type: Post Treatment/Finished Water Sample

DOH #	Analyte	Results	Units	SRL	Trigger	MCL	Method	Analyst
Total Trihalo Methane (TTHM's)								
27	CHLOROFORM	6.1	ug/L	0.5	0.5		EPA_524.2_TTHM	NB
28	BROMODICHLOROMETHANE	7.3	ug/L	0.5	0.5		EPA_524.2_TTHM	NB
29	DIBROMOCHLOROMETHANE	6.0	ug/L	0.5	0.5		EPA_524.2_TTHM	NB
30	BROMOFORM	3.1	ug/L	0.5	0.5		EPA_524.2_TTHM	NB
31	TOTAL TRIHALOMETHANE	22.5	ug/L	0.5	0.5	80	EPA_524.2_TTHM	NB
HaloAcetic Acids (HAA's)								
411	MONOCHLOROACETIC ACID	ND	ug/L	2			EPA_552.3_DBP	GL
412	DICHLOROACETIC ACID	5.2	ug/L	1			EPA_552.3_DBP	GL
413	TRICHLOROACETIC ACID	1.8	ug/L	1			EPA_552.3_DBP	GL
414	MONOBROMOACETIC ACID	ND	ug/L	1			EPA_552.3_DBP	GL
415	DIBROMOACETIC ACID	3.1	ug/L	1			EPA_552.3_DBP	GL
416	HAA(5)	10.1	ug/L	1	15	60	EPA_552.3_DBP	GL
417	BROMOCHLOROACETIC ACID	4.8	ug/L	1			EPA_552.3_DBP	GL

MCL = (Maximum Contaminant Level) allowed by the State of Washington.

ND = (Not Detected) Compound was analyzed and not detected at a level greater than or equal to the SRL.

SRL = (State Reporting Level) The minimum reporting level required by Washington State Department of Health (DOH).

Trigger Level = DOH drinking water response level. System with compounds detected at concentrations in excess of this level are required to take additional samples.

< = (less than) indicates the analyte was below the detection limit.

OT = Out of Hold Time

174 79874



Water Chemical Analysis

174 79875

Client: King Water Company
PO Box 2243
Oak Harbor, WA 98277

Phone: (360) 914-1395

Email: jeremy@kingwater.com

Invoice Number: 22-20248
PO Number:
Project Name: TTHM/HAAApproved By: 

PWS Information

Date Collected: 11/28/2022
System Number: 74000
Lab Sample Number: 174 79875
Sample Location: Sample: Rolling Hills 1630 Douglas
Sample Purpose: Routine Compliance
Sample Composition: Flowing Distribution Sample

Sample Collected by:

System Group Type:
System Name: ROLLING HILLS-GLENCAIRN
County: ISLAND
Source Number: 92
Date Received: 11/29/2022
Date Analyzed: 12/1/2022
Date Reported: 12/20/2022
Sample Type: Post Treatment/Finished Water Sample

DOH #	Analyte	Results	Units	SRL	Trigger	MCL	Method	Analyst
Total Trihalo Methane (TTHM's)								
27	CHLOROFORM	5.7	ug/L	0.5	0.5		EPA_524.2_TTHM	NB
28	BROMODICHLOROMETHANE	6.8	ug/L	0.5	0.5		EPA_524.2_TTHM	NB
29	DIBROMOCHLOROMETHANE	5.9	ug/L	0.5	0.5		EPA_524.2_TTHM	NB
30	BROMOFORM	3.1	ug/L	0.5	0.5		EPA_524.2_TTHM	NB
31	TOTAL TRIHALOMETHANE	21.5	ug/L	0.5	0.5	80	EPA_524.2_TTHM	NB
HaloAcetic Acids (HAA's)								
411	MONOCHLOROACETIC ACID	ND	ug/L	2			EPA_552.3_DBP	GL
412	DICHLOROACETIC ACID	5.2	ug/L	1			EPA_552.3_DBP	GL
413	TRICHLOROACETIC ACID	1.6	ug/L	1			EPA_552.3_DBP	GL
414	MONOBROMOACETIC ACID	ND	ug/L	1			EPA_552.3_DBP	GL
415	DIBROMOACETIC ACID	2.7	ug/L	1			EPA_552.3_DBP	GL
416	HAA(5)	9.5	ug/L	1	15	60	EPA_552.3_DBP	GL
417	BROMOCHLOROACETIC ACID	5.2	ug/L	1			EPA_552.3_DBP	GL

MCL = (Maximum Contaminant Level) allowed by the State of Washington.

ND = (Not Detected) Compound was analyzed and not detected at a level greater than or equal to the SRL.

SRL = (State Reporting Level) The minimum reporting level required by Washington State Department of Health (DOH).

Trigger Level = DOH drinking water response level. System with compounds detected at concentrations in excess of this level are required to take additional samples.

< = (less than) indicates the analyte was below the detection limit.

OT = Out of Hold Time

174 79875