



Exact Scientific Services, Inc.

1355 Pacific Place  
Suite 101  
Ferndale, WA 98248

Phone: (360) 733-1205  
Fax: (888) 818-2978  
Email: lab@exactscientific.com

## Water Chemical Analysis

174 26155

**Client:** King Water Company  
PO Box 2243  
Oak Harbor, WA 98277

**Phone:** (360) 914-1395

**Email:** jeremy@kingwater.com

**Invoice Number:** 23-06955  
**PO Number:**  
**Project Name:**

**Approved By:**

### PWS Information

Date Collected: 4/21/2023

**System Number:** 74000

Lab Sample Number: 174 26155

Sample Location: Sample: Rolling Hills S04 = well 1R

Sample Purpose: Routine Compliance

Sample Composition: Samples from a single source

Sample Collected by:

System Group Type:

**System Name:** ROLLING HILLS-GLENCAIRN

County: ISLAND

Source Number: 04

Date Received: 4/25/2023

Date Analyzed: 4/26/2023

Date Reported: 5/3/2023

Sample Type: Pretreatment/RawWater Sample

DOH #	Analyte	Results	Units	SRL	Trigger	MCL	Method	Analyst
<b>State Regulated</b>								
16	CONDUCTIVITY	819	uS/cm	70	---	700	SM_2510B	EC
<b>EPA Regulated (Secondary)</b>								
21	CHLORIDE	66.8	mg/L	20	---	250	300.0_Cl	KV

MCL = (Maximum Contaminant Level) allowed by the State of Washington.

ND = (Not Detected) Compound was analyzed and not detected at a level greater than or equal to the SRL.

SRL = (State Reporting Level) The minimum reporting level required by Washington State Department of Health (DOH).

Trigger Level = DOH drinking water response level. System with compounds detected at concentrations in excess of this level are required to take additional samples.

< = (less than) indicates the analyte was below the detection limit.

OT = Out of Hold Time RR = Revised Result

174 26155



Exact Scientific Services, Inc.

1355 Pacific Place  
Suite 101  
Ferndale, WA 98248

Phone: (360) 733-1205  
Fax: (888) 818-2978  
Email: lab@exactscientific.com

## Water Chemical Analysis

174 26156

**Client:** King Water Company  
PO Box 2243  
Oak Harbor, WA 98277

**Phone:** (360) 914-1395

**Email:** jeremy@kingwater.com

**Invoice Number:** 23-06955

**PO Number:**

**Project Name:**

**Approved By:**

### PWS Information

**Date Collected:** 4/21/2023

**System Number:** 74000

**Lab Sample Number:** 174 26156

**Sample Location:** Sample: Rolling Hills S05 = well 4

**Sample Purpose:** Routine Compliance

**Sample Composition:** Samples from a single source

**Sample Collected by:**

**System Group Type:**

**System Name:** ROLLING HILLS-GLENCAIRN

**County:** ISLAND

**Source Number:** 05

**Date Received:** 4/25/2023

**Date Analyzed:** 4/26/2023

**Date Reported:** 5/3/2023

**Sample Type:** Pretreatment/RawWater Sample

DOH #	Analyte	Results	Units	SRL	Trigger	MCL	Method	Analyst
<b>State Regulated</b>								
16	CONDUCTIVITY	1070	uS/cm	70	---	700	SM_2510B	EC
<b>EPA Regulated (Secondary)</b>								
21	CHLORIDE	108	mg/L	20	---	250	300.0_Cl	KV

MCL = (Maximum Contaminant Level) allowed by the State of Washington

ND = (Not Detected) Compound was analyzed and not detected at a level greater than or equal to the SRL

SRL = (State Reporting Level) The minimum reporting level required by Washington State Department of Health (DOH)

Trigger Level = DOH drinking water response level. System with compounds detected at concentrations in excess of this level are required to take additional samples

< = (less than) indicates the analyte was below the detection limit

OT = Out of Hold Time RR = Revised Result

174 26156