



Exact Scientific Services, Inc.

1355 Pacific
Su
Ferndale, WA

Phone: (360) 73
Fax: (888) 81

Email: lab@exactscienci

174 C

Water Bacteriological Analysis

Sample: 794 Gem Ct.
Client: King Water Company
PO Box 2243
Oak Harbor, WA 98277

Invoice Number: 24-00304

PO Number:

Project Name:

Report Date: 1/5/2024

Phone: (360) 678-5336

Email: cerickson@nwnaturalwaterservices.com

Approved By:

Sample Information

Date Collected:	1/4/2024	Date Received:	1/4/2024
Sample Collected by:	Jeremy	Source Number:	0
Sample Purpose:	Investigative		
Sample Type:	Post Treatment/Finished Water Sample	Chlorine Res:	
Sample Composition:	Coliform Samples		
Sample Collection:	Flowing		
Suitability:	Yes		

System Number: 76520

System Name: SCENIC HEIGHTS W A INC

Lab #: 01016		Sample: 794 Gem Ct.				
Analyte	Results	Units	Detection Limit	Method	Analyst	Date An
TOTAL COLIFORM	Satisfactory	/100ml	1	SM_9223B	SK	1/5/2
E. COLI	Absent	/100ml	1	SM_9223B	SK	1/5/2