



Burlington, WA Corporate Laboratory (a)
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
 Bellingham, WA Microbiology (b)
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
 9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802
 Corvallis, OR Microbiology/Chemistry (d)
 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946
 Bend, OR Microbiology (e)
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



OR NELAP 4072
 Page 1 of 1

LEAD & COPPER RULE REPORT

Client Name: King Water Company-NW Natural Water Services
 107 S Main St
 Coupeville, WA 98239

Reference Number: 24-20600
 Project: ROLLING HILLS 74000F

System ID Number: **74000F**
 Lab Number: 046-40007
 Sample Purpose: C - Compliance
 Sample Composition: Single Source

System Group Type: A
 System Name: ROLLING HILLS
 County:
 Source Number: 93 - Standing Water (Pb&Cu)
 Multiple Sources:

Approved By: anp

Authorized By:

Lawrence J Henderson, PhD
 Director of Laboratories, Vice President

Date Received: 7/9/2024
 Date Reported: 7/25/24
 Sample Type: D - Drinking Water

Lab Number	Date Collected	Site / Location	PRM #	Analyte Name	Result	Units	AL	SRL	METHOD	Lab	Analyzed	Comments
046-40007	6/28/2024	- 1664 Allyson	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	7/23/24	
			23	COPPER	0.160	mg/L	1.3	0.005	200.8	a	7/23/24	
046-40008	7/2/2024	- 1700 Phillip St	9	LEAD	0.0021	mg/L	0.015	0.001	200.8	a	7/23/24	
			23	COPPER	0.0265	mg/L	1.3	0.005	200.8	a	7/23/24	
046-40009	6/26/2024	- 969 Riepma	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	7/23/24	
			23	COPPER	0.0532	mg/L	1.3	0.005	200.8	a	7/23/24	
046-40010	6/28/2024	930 Diane Ave	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	7/23/24	
			23	COPPER	0.0291	mg/L	1.3	0.005	200.8	a	7/23/24	
046-40011	6/26/2024	1158 Allyson St	9	LEAD	0.0032	mg/L	0.015	0.001	200.8	a	7/23/24	
			23	COPPER	0.159	mg/L	1.3	0.005	200.8	a	7/23/24	

NOTES:

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Specified Reporting Limit (SRL).

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

If you have any questions concerning this report contact Lawrence J Henderson, PhD, Director of Laboratories, Vice President, at the toll-free phone number above.