

Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: **Rolling Hills Glencairn**
1126 N Sidney
Oak Harbor, WA 98277

Reference Number: 25-07172
Project: Rolling Hills Glencairn Bacteria

System Name: ROLLING HILLS-GLENCAIRN
System ID Number: 74000F
DOH Source Number: 00 - Distribution Sample (Bacteria)
Sample Type: D - Drinking Water
Sample Purpose: C - Compliance
Sample Location: 1630 Douglas Ave
County: Island
Sampled By: EWS
Sampler Phone:

Repeat Sample Number:
Lab Number: 164-15347
Field ID: Rolling Hills Glencairn B
Date Collected: 3/11/25 09:40
Date Received: 3/11/25
Date Set: 3/11/25 18:19
Date Analyzed: 3/12/25 15:29
Report Date: 3/13/25
Comment: Cl2: 0.42
Approved By: ckk,mlp

Authorized by:



Ceann K Knox
Lab Manager, Bellingham

DOH#	PARAMETER	RESULT	Qualifier	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	Satisfactory, Coliforms Absent		per 100mL	jln	SM9223 B	m_250311b	
3	E. COLI	Absent		per 100mL		SM9223 B	m_250311b	

If the sample is unsatisfactory you can get information on well disinfection at Washington State Department of Health:

WA DOH: <https://doh.wa.gov/community-and-environment/drinking-water/disinfection>

NOTES:

If the result is Unsatisfactory, three (3) repeat samples and groundwater source samples are required for Group A Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.

If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.

*If data qualifiers are present, see accompanying Qualifier Definition report.