

Client Sample Results

Client: Oak Harbor Water Management
 Project/Site: HAA / THMS Compliance

Job ID: 110-7909-1

Client Sample ID: RH 2: /630 Douglas

Lab Sample ID: 110-7909-2

Date Collected: 03/24/26 12:25

Matrix: Drinking Water

Date Received: 03/24/26 15:55

PWSID Number: 74000F

Method: EPA-DW 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,4-Difluorobenzene (Surr)	105		70 - 130		03/26/26 18:24	1

Method: EPA 552.3 THAA - Total Haloacetic Acids (GC)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Total Haloacetic Acids 5	17		1.0	ug/L			03/27/26 22:35	1

Method: EPA 552.3 - Haloacetic Acids (HAAs) (GC)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Bromochloroacetic acid	7.6		1.0	ug/L		03/27/26 12:17	03/27/26 22:35	1
Dibromoacetic acid	9.1		1.0	ug/L		03/27/26 12:17	03/27/26 22:35	1
Dichloroacetic acid	4.9		1.0	ug/L		03/27/26 12:17	03/27/26 22:35	1
Trichloroacetic acid	2.9		1.0	ug/L		03/27/26 12:17	03/27/26 22:35	1
Chloroacetic acid	ND		2.0	ug/L		03/27/26 12:17	03/27/26 22:35	1
Bromoacetic acid	ND		1.0	ug/L		03/27/26 12:17	03/27/26 22:35	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2-Bromopropionic acid (Surr)	71		70 - 130	03/27/26 12:17	03/27/26 22:35	1

Client Sample ID: Water Plant

Lab Sample ID: 110-7909-3

Date Collected: 03/24/26 12:15

Matrix: Drinking Water

Date Received: 03/24/26 15:55

General Chemistry

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Ammonia as N (EPA 350.1)	0.30		0.010	mg/L			03/26/26 20:11	1