

Client Sample Results

Client: Oak Harbor Water Management
Project/Site: Rolling Hills

Job ID: 110-7075-1

Client Sample ID: 1056 Riepma

Lab Sample ID: 110-7075-1

Date Collected: 03/10/26 10:55

Matrix: Drinking Water

Date Received: 03/10/26 14:58

PWSID Number: 74000F

Method: SM 9223B - Coliforms, Total, and E.Coli (Colilert - Presence/Absence)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Escherichia coli	ABSENT			NONE			03/10/26 17:43	1
Coliform, Total	ABSENT			NONE			03/10/26 17:43	1