

Client Sample Results

Client: Oak Harbor Water Management
Project/Site: DW compliance

Job ID: 110-15369-1

Client Sample ID: PENN COVE WATER & SEWER DISTRICT

Lab Sample ID: 110-15369-1

66950 839 WALKER

Date Collected: 08/18/26 09:00

Matrix: Drinking Water

Date Received: 08/18/26 13:52

PWSID Number: 66950

Method: SM 9223B - Coliforms, Total, and E.Coli (Colilert - Presence/Absence)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Escherichia coli	ABSENT			NONE			08/18/26 17:38	1
Coliform, Total	ABSENT			NONE			08/18/26 17:38	1

Client Sample ID: SCENIC HEIGHTS 76520R 798 STARWANA

Lab Sample ID: 110-15369-2

Date Collected: 08/18/26 09:15

Matrix: Drinking Water

Date Received: 08/18/26 13:52

PWSID Number: 76520R

Method: SM 9223B - Coliforms, Total, and E.Coli (Colilert - Presence/Absence)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Escherichia coli	ABSENT			NONE			08/18/26 17:38	1
Coliform, Total	ABSENT			NONE			08/18/26 17:38	1

Client Sample ID: BONNIE VIEW 07700B 1436 BONNIEVIEW

Lab Sample ID: 110-15369-3

Date Collected: 08/18/26 09:30

Matrix: Drinking Water

Date Received: 08/18/26 13:52

PWSID Number: 07700B

Method: SM 9223B - Coliforms, Total, and E.Coli (Colilert - Presence/Absence)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Escherichia coli	ABSENT			NONE			08/18/26 17:38	1
Coliform, Total	ABSENT			NONE			08/18/26 17:38	1

Client Sample ID: BONNIE VIEW 07700B 1436 BONNIEVIEW

Lab Sample ID: 110-15369-4

Date Collected: 08/18/26 09:30

Matrix: Drinking Water

Date Received: 08/18/26 13:52

PWSID Number: 07700B

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenic	0.0060		0.0010	mg/L			08/21/26 16:38	1

Client Sample ID: METERWELL 05156U 607 SCENEIC

Lab Sample ID: 110-15369-5

HEIGHTS

Date Collected: 08/18/26 09:45

Matrix: Drinking Water

Date Received: 08/18/26 13:52

PWSID Number: 05156U

Method: SM 9223B - Coliforms, Total, and E.Coli (Colilert - Presence/Absence)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Escherichia coli	ABSENT			NONE			08/18/26 17:38	1
Coliform, Total	ABSENT			NONE			08/18/26 17:38	1

Client Sample ID: ROLLING HILLS GLENCAIRN 74000 F 1630

Lab Sample ID: 110-15369-6

DOUGLAS

Date Collected: 08/18/26 10:00

Matrix: Drinking Water

Date Received: 08/18/26 13:52

PWSID Number: 74000

Method: SM 9223B - Coliforms, Total, and E.Coli (Colilert - Presence/Absence)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Escherichia coli	ABSENT			NONE			08/18/26 17:38	1
Coliform, Total	ABSENT			NONE			08/18/26 17:38	1

Eurofins Washington

Client Sample Results

Client: Oak Harbor Water Management
Project/Site: DW compliance

Job ID: 110-15369-1

Client Sample ID: REEDER BAY AB189A PUMPHOUSE

Lab Sample ID: 110-15369-7

Date Collected: 08/18/26 10:30

Matrix: Drinking Water

Date Received: 08/18/26 13:52

PWSID Number: AB189A

Method: SM 9223B - Coliforms, Total, and E.Coli (Colilert - Presence/Absence)								
Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Escherichia coli	ABSENT			NONE			08/18/26 17:38	1
Coliform, Total	ABSENT			NONE			08/18/26 17:38	1

Client Sample ID: LITTLE VALLEY APARTMENTS 220573

Lab Sample ID: 110-15369-8

30160 LVA

Date Collected: 08/18/26 11:00

Matrix: Drinking Water

Date Received: 08/18/26 13:52

PWSID Number: 220573

Method: SM 9223B - Coliforms, Total, and E.Coli (Colilert - Presence/Absence)								
Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Escherichia coli	ABSENT			NONE			08/18/26 17:38	1
Coliform, Total	ABSENT			NONE			08/18/26 17:38	1

Client Sample ID: BAYVIEW ESTATES 04956T 2765 NUTMEG

Lab Sample ID: 110-15369-9

Date Collected: 08/18/26 11:30

Matrix: Drinking Water

Date Received: 08/18/26 13:52

PWSID Number: 04956T

Method: SM 9223B - Coliforms, Total, and E.Coli (Colilert - Presence/Absence)								
Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Escherichia coli	ABSENT			NONE			08/18/26 17:38	1
Coliform, Total	ABSENT			NONE			08/18/26 17:38	1