Client Sample ID: 74000F Rolling Hills-Glencairn - Douglas

Lab Sample ID: 110-18593-1
Date Collected: 10/27/26 11:30
Matrix: Drinking Water
Date Received: 10/27/26 16:03
PWSID Number: 74000F

Method: EPA-DW 524.2 - Total Trihalomethanes

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Trihalomethanes, Total	83		0.50		ug/L			11/04/26 03:30	1

Method: EPA-DW 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Chloroform (Trichloromethane)	11		0.50		ug/L			11/04/26 03:30	1
Bromodichloromethane	23		0.50		ug/L			11/04/26 03:30	1
Dibromochloromethane	32		0.50		ug/L			11/04/26 03:30	1
Bromoform	17		0.50		ug/L			11/04/26 03:30	1

Surrogate	*%Recovery*	*Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
1,2-Dichloroethane-d4 (Surr)	*107*		*70 - 130*		*11/04/26 03:30*	*1*
4-Bromofluorobenzene (Surr)	*102*		*70 - 130*		*11/04/26 03:30*	*1*
Toluene-d8 (Surr)	*94*		*70 - 130*		*11/04/26 03:30*	*1*

Method: SM 6251B - Haloacetic Acids (HAAs) (GC)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Monobromoacetic acid	1.7		1.0		ug/L		11/04/26 08:40	11/06/26 03:54	1
Monochloroacetic acid	ND		2.0		ug/L		11/04/26 08:40	11/06/26 03:54	1
Dibromoacetic acid	10		1.0		ug/L		11/04/26 08:40	11/06/26 03:54	1
Dichloroacetic acid	7.1		1.0		ug/L		11/04/26 08:40	11/06/26 03:54	1
Trichloroacetic acid	5.4		1.0		ug/L		11/04/26 08:40	11/06/26 03:54	1
Bromochloroacetic acid	10		1.0		ug/L		11/04/26 08:40	11/06/26 03:54	1

Surrogate	*%Recovery*	*Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
2,3-Dibromopropionic acid	*115*		*70 - 130*	*11/04/26 08:40*	*11/06/26 03:54*	*1*

Method: SM 6251B - Total Haloacetic Acids (GC)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Total Haloacetic Acids 5	24		2.0		ug/L			11/06/26 03:54	1

Client Sample ID: 74000F Rolling Hills-Glencairn - Boat Launch

Lab Sample ID: 110-18593-2
Date Collected: 10/27/26 11:30
Matrix: Drinking Water
Date Received: 10/27/26 16:03
PWSID Number: 74000F

Method: EPA-DW 524.2 - Total Trihalomethanes

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Trihalomethanes, Total	80		0.50		ug/L			11/04/26 03:52	1

Method: EPA-DW 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Chloroform (Trichloromethane)	9.0		0.50		ug/L			11/04/26 03:52	1
Bromodichloromethane	22		0.50		ug/L			11/04/26 03:52	1
Dibromochloromethane	33		0.50		ug/L			11/04/26 03:52	1
Bromoform	16		0.50		ug/L			11/04/26 03:52	1

Surrogate	*%Recovery*	*Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
1,2-Dichloroethane-d4 (Surr)	*102*		*70 - 130*		*11/04/26 03:52*	*1*
4-Bromofluorobenzene (Surr)	*98*		*70 - 130*		*11/04/26 03:52*	*1*
Toluene-d8 (Surr)	*96*		*70 - 130*		*11/04/26 03:52*	*1*

Client Sample ID: 74000F Rolling Hills-Glencairn - Boat Launch

Lab Sample ID: 110-18593-2

Date Collected: 10/27/26 11:30
Date Received: 10/27/26 16:03

Matrix: Drinking Water
PWSID Number: 74000F

Method: SM 6251B - Haloacetic Acids (HAAs) (GC)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Monobromoacetic acid	1.7		1.0		ug/L		11/04/26 08:40	11/05/26 21:23	1
Monochloroacetic acid	ND		2.0		ug/L		11/04/26 08:40	11/05/26 21:23	1
Dibromoacetic acid	11		1.0		ug/L		11/04/26 08:40	11/05/26 21:23	1
Dichloroacetic acid	7.6		1.0		ug/L		11/04/26 08:40	11/05/26 21:23	1
Trichloroacetic acid	5.5		1.0		ug/L		11/04/26 08:40	11/05/26 21:23	1
Bromochloroacetic acid	11		1.0		ug/L		11/04/26 08:40	11/05/26 21:23	1

Surrogate	*%Recovery*	*Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
2,3-Dibromopropionic acid	*124*		*70 - 130*	*11/04/26 08:40*	*11/05/26 21:23*	*1*

Method: SM 6251B - Total Haloacetic Acids (GC)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Total Haloacetic Acids 5	26		2.0		ug/L			11/05/26 21:23	1